

City of Rehoboth Beach

Sharon Lynn
City Manager

slynn@cityofrehoboth.com

July 6, 2017



City Hall
P.O. Box 1163
229 Rehoboth Avenue
Rehoboth Beach, Delaware 19971
Telephone 302-227-4641
www.cityofrehoboth.com

City of Rehoboth Beach Force Main
Project Number: 2017-002
Addendum #1

To Bidders:

This Addendum #1 is hereby made part of the Bidding Documents on which the Contract will be based, and is issued to modify, explain and/or correct the original Bidding Documents. Please submit bids and be otherwise governed accordingly. **Receipt of this Addendum must be acknowledged on Page 00410-1 of Section 00410 Bid Form.**

RESPONSES TO QUESTIONS

Question 1

Can 24" DR18 Diamond Lok Restrained Joint PVC Pressure Pipe be approved and included in the specifications for installation where 24" restrained joints are required?

Response

Yes. Diamond Lok and Eagle Loc will be approved as an acceptable form of restraint.

CHANGES TO BIDDING DOCUMENTS

1. Invitation to Bid, Page 00050-1: CHANGE "until 2:00 pm, Tuesday, July 11, 2017" to "until 2:00 PM, Thursday, July 13, 2017".
2. Section 02740 2.02, A. 1. b., ADD the following at the end of the sentence:

Push-on restraint joint gaskets meeting AWWA C900 pressure pipe standards can be used in place of mechanical restraint harness. Restrained joint gaskets shall be as manufactured and supplied by Diamond Plastics, Diamond Lok-21 and JM Eagle, Eagle Loc 900.
3. DELETE Section 00410 Bid Form in its entirety and REPLACE with the attached Section 00410 Bid Form.

ATTACHMENTS

1. Force Main #2017-001 Pre-Bid Meeting Minutes
2. Force Main City Project #2017-002 Pre-Bid Meeting Sign-in Sheet
3. Section 00410 Bid Form

Sincerely,

Sharon Lynn
City Manager