

Sharon Lynn
City Manager

slynn@cityofrehoboth.com



City Hall
P.O. Box 1163
229 Rehoboth Avenue
Rehoboth Beach, Delaware 19971
Telephone 302-227-4641
www.cityofrehoboth.com

July 14, 2017

City of Rehoboth Beach Ocean Outfall
Project Number: 2017-001
Addendum #4

To Bidders:

This Addendum #4 is hereby made part of the Bidding Documents on which the Contract will be based, and is issued to modify, explain and/or correct the original Bidding Documents. Please submit bids and be otherwise governed accordingly.
Receipt of this Addendum must be acknowledged on Page 00410-1 of Section 00410 Bid Form.

CHANGES TO BIDDING DOCUMENTS

1. DELETE Addendum #2 Question 3 response in its entirety, and REPLACE with the following:

The use of a conductor casing at the HDD exit to contain the drilling fluids during the reaming process and product pipe installation (as described in Specification Section 02200 Paragraph 1.01.D), may be replaced by a substitute method that equally contains the drilling fluid and prevents the drilling fluid from becoming subject to dispersal within the water column, and allows for the extraction, removal and proper disposal of the drilling fluid; subject to the approval of the Engineer.

Sincerely,

Sharon Lynn
City Manager